



Republic of the Philippines
CAGAYAN DE ORO CITY WATER DISTRICT
Corrales Avenue, Brgy. 27, Cagayan de Oro City
Misamis Oriental

SUPPLEMENTAL NOTICE No. 1
for
1 LOT SUPPLY AND DELIVERY OF B.I. PIPES OF VARIOUS SIZES
(PR No. 23-04-07-0053)
August 4, 2023

AS POSTED	SHOULD BE READ AS
Technical Specifications	
8.) 2 length, Pipe, B.I.; S40, 450mmØ x 6m x 14.27mm thk. (min.)	
<p>CAGAYAN DE ORO CITY WATER DISTRICT QUALITY CONTROL COMMITTEE for PIPES AND SERVICE CONNECTION MATERIALS cowl_dcc@yahoo.com</p> <p>450 mmØ (18"Ø) x 6 m long B.S. PIPE SCH 40</p> <p>MATERIAL SPECIFICATIONS</p> <p>Make : Black Steel Outside Diameter : 457 mm (minimum) Wall Thickness : 14.27 mm (minimum) Length : 6 meters Working Pressure : 150 psi Other Requirements : Original Manufacturer's Product Brochures / Manual / Literatures Specify Delivery Packaging</p> <p>DRAWINGS</p>  <p>EULIJUN B. SALARDA Member</p> <p>ARNOLD CHRISTOPHER G. CAINGLES Member</p> <p>GRACE JOY C. YAÑEZ Member</p> <p>RODNEY E. GARCIA Member / Secretary</p> <p>REYVIC P. GALARRITA Member / Internal Control</p> <p>MARITEL D. BONDAL Chairman</p>	<p>CAGAYAN DE ORO CITY WATER DISTRICT QUALITY CONTROL COMMITTEE for PIPES AND SERVICE CONNECTION MATERIALS cowl_dcc@yahoo.com</p> <p>450 mmØ (18"Ø) x 6 m long B.S. PIPE SCH 40</p> <p>MATERIAL SPECIFICATIONS</p> <p>Make : Black Steel Outside Diameter : 457 mm (minimum) Wall Thickness : 14.27 mm (minimum) Length : 6 meters Working Pressure : 150 psi Other Requirements : Original Manufacturer's Product Brochures / Manual / Literatures Specify Delivery Packaging</p> <p>DRAWINGS</p>  <p>EULIJUN B. SALARDA Member</p> <p>ARNOLD CHRISTOPHER G. CAINGLES Member</p> <p>GRACE JOY C. YAÑEZ Member</p> <p>RODNEY E. GARCIA Member / Secretary</p> <p>REYVIC P. GALARRITA Member / Internal Control</p> <p>MARITEL D. BONDAL Chairman</p>
(Not stated)	Note: All pipes are to be secured with plastic pipe cover at both ends.

Prepared by:

Nikl

JUSTINE NICOLE C. BELEN
BAC Secretariat Staff

Checked by:

Joseph A. Magriña

JOSEPH A. MAGRIÑA
Head, BAC Secretariat

Noted by:

Edna S. Najal
EDNA S. NAJAL
BAC Chairperson
Nikki.Belen
8/3/2023 4:15 PM